NOTES:

- 1. ALL INSIDE DROP PIPING SHALL BE P.V.C. PIPE, SCHEDULE 40.
- PRIME AND CEMENT ALL JOINTS AS RECOMMENDED BY THE MANUFACTURER.
- 3. DROP CONNECTION PIPE AND FITTINGS TO BE SAME SIZE AS ENTERING PIPE.
- 4. CLAMPS SHALL BE 1 1/2 IN. BY 12 GAUGE STAINLESS STEEL, ANCHORED TO MANHOLE WALL WITH 2 1/2 IN. CADMIUM PLATED BOLTS.
- 5. FOR CONNECTIONS TO MANHOLES WITH EXIT PIPES 10 IN.
 DIAMETER OR LARGER, MATCH THE FLOWLINE OF THE DROP PIPE
 TO THE CROWN OF THE EXIT PIPE.

COUNTY OF PLACER DEPARTMENT OF PUBLIC WORKS

INSIDE DROP CONNECTION
SANITARY SEWER 4", 6" & 8" ONLY

DATE: JULY, 2005 NTS PLATE **U-16** (91-2)

PPROVED:

DIRECTOR OF PUBLIC WORKS

