

ADVISORY NOTICE FOR GASOLINE DISPENSING FACILITIES WITH UNDERGROUND STORAGE TANKS

This advisory notice is provided for owners and operators of gasoline dispensing facilities (GDF) with underground storage tanks who have a Permit to Operate with the Placer County Air Pollution Control District (District).

Annual Testing - You must conduct performance testing annually (within 30 days of the anniversary of the most recent successful test per District policy). Testing requirements are specified in your Permit to Operate and the California Air Resources Board's (CARB) vapor recovery Executive Orders. The District must be notified at least 15 days prior to the testing. Test results must be received at the District within 30 days of the testing date. All test failures must be noted in the results received by the District.

District staff will observe annual tests, as scheduling, resources, and priorities allow, verifying they are conducted properly. When District staff observes the annual tests, you will be charged a source test observation fee, currently at the District's general labor rate of \$109.07 per hour for fiscal year 2015/2016. The District anticipates this will take four to six hours for most underground storage tanks. This is in addition to the annual billing for test report review.

Reinspection Fees for 7-Day and Out of Order Defects - During the District's annual inspection, if equipment defects are observed, they will be noted on the annual inspection form as either "Repair within 7-Days" or "Tagged Out of Order". When a 7-day repair is noted, the equipment may still be used while it is pending repair. Equipment tagged out of order, will receive an "Out of Order" tag and must be locked out of order and not used until the equipment has been repaired. Once the repair has been completed, the "Out of Order" tag must be returned to the District, and the equipment may be placed back in operation. A reinspection will be performed to verify that the non-complying items are corrected and stations will be charged accordingly. Significant defects and delayed 7-day repairs are subject to enforcement action.

Inspection, Maintenance and Recordkeeping - Routine (weekly, quarterly, and yearly) inspections and maintenance of the gasoline dispensing vapor recovery components are required to be performed and documented. The findings of these inspections including the maintenance and repairs that are performed must be documented in a maintenance log and inspection records and reports.

Recordkeeping forms that may be used to fulfill these requirements are provided on the District's website, www.placer.ca.gov/departments/air/vaporrecovery. When a significant defect is observed during routine self-inspection, the affected piece of equipment must be placed out of service until it is repaired. A list of significant defects can be found on the Vapor Recovery Equipment Defects List at, www.arb.ca.gov/vapor/title17/defecclst.pdf.

For stations with In-Station Diagnostics (ISD), failure alarms must be documented in the maintenance log. After a failure alarm occurs, it must be responded to and cleared by a certified contractor. Alarms that occur between November 1 – March 31, and that are specifically listed in the [CARB Overpressure Alarm Advisory 405-C](#), are excluded from this requirement and may be reset by the station owner or operator.

The Permit to Operate, applicable Phase I and Phase II Executive Orders and Installation, Operation and Maintenance Manuals, and any applicable CARB approval letters, shall be maintained at the facility.

Low Permeation Hose Requirement for Assist (Healy) Systems – As specified in [CARB Advisory 343](#), effective July 1, 2015, the Veyance Technologies Inc. Futura HVR Low Perm Hose and the Franklin Fueling Systems Healy Model 75 Low Perm Hose are the only allowable replacement hoses for Assist (Healy) Systems. Effective September 24, 2018, all gasoline dispensing facilities with an Assist (Healy) System must upgrade to a certified low permeation hose. The low permeation hoses shall be installed and maintained in accordance with the manufacturer's installation and maintenance instructions.

Compliance Assistance – Facilities may request a compliance assistance to review recordkeeping and maintenance requirements by contacting Molly Johnson at (530) 745-2326 or mjohnso@placer.ca.gov.