

2019 CALIFORNIA BUILDING STANDARDS CODE OF REGULATIONS TITLE 24

FINAL INSPECTION CHECKLIST

PERMIT: _____ ADDRESS: _____

The following items are to be reviewed for completion by the contractor/owner prior to scheduling an inspection. Each item is to be checked as “OK” or “N/A”. The person reviewing these items will need to sign and date this form. Present the completed form to the Building Inspector prior to commencing the inspection.

WARNING: Failure to complete this form may delay the inspection and necessitate a reinspection fee. Prior to this inspection, all required sequential inspections and correction notices must be completed. This is not an all-inclusive list and additional items may be required as determined during the inspection.

THIS INSPECTION CANNOT BE PHASED: At time of this inspection all work shall be completed

PARTIAL AND PHASED INSPECTIONS: Partial and phased inspections identified during the inspection process will require additional inspection fees per Building Department Fee Schedule.

FINAL (600 Combo)

- | | OK | N/A | |
|----|--------------------------|--------------------------|---|
| 1. | <input type="checkbox"/> | <input type="checkbox"/> | Construction site is safe for inspection. Boards with nails and excessive debris removed. Ladders and scaffold are removed. |
| 2. | <input type="checkbox"/> | <input type="checkbox"/> | Permanent Best Management Practices (BMP’s) are in place and established as required for storm water control, temporary BMP’s are removed. |
| 3. | <input type="checkbox"/> | <input type="checkbox"/> | Approved plans and permit card are on the job-site. CRC §R106.3.1 & 105.7 |
| 4. | <input type="checkbox"/> | <input type="checkbox"/> | Building must have power for testing circuits and circuit tester. |
| 5. | <input type="checkbox"/> | <input type="checkbox"/> | Provide safe and adequate size ladder(s) for roof and attic inspection. Ladder shall extend a min. of 36” above roof edge and be full height to attic access scuttle. |

PERMITS, PLANS AND DOCUMENTATION

- | | | | |
|----|--------------------------|--------------------------|--|
| 6. | <input type="checkbox"/> | <input type="checkbox"/> | All revisions submitted, approved and attached to plans & plan check fees paid. |
| 7. | <input type="checkbox"/> | <input type="checkbox"/> | Required “Conditions of Approval” from other departments have been cleared. (Environmental Health, Public Works, Planning, Engineering & Survey, Air Pollution Departments and Fire Department). |
| 8. | <input type="checkbox"/> | <input type="checkbox"/> | Defensible space final inspection completed by Fire Department (if WUI requirements apply). |

9. Fire Sprinklers final inspection to be completed by the Fire Department or the Authority having jurisdiction (Only for new dwellings)
10. Placer County MOU projects within the Lake Tahoe basin require that all TRPA requirements be completed prior to, but no later than the building's final inspection.
11. Verify compliance with approved plans and required sequential inspections are signed off.
12. Stucco certification (For one and two coat systems)
13. Provide originals of the registered form, Certificate of Verification (CF-3R) form, when Field Verification and/or Diagnostic Testing are required by the CF1R form for the field inspector at final inspection. Copies shall be provided in the Building Owner's Manual.
14. Provide PEX water piping certification that meets the flushing, tagging procedures and installation is in compliance with the requirements of the code. CPC §604

EXTERIOR

15. Address numbers shall be placed on house, plainly legible and visible from the street or road fronting the property. Numbers shall contrast with background. Numbers shall be Arabic numerals or alphabetical letters with a min. height of 4" and min. 1/2" stroke, reflectorized or may be a minimum 5" high. CRC §R319 and PCC 15.04.160
16. All exterior wall coverings shall be complete and wood painted. CRC §R317
17. All penetrations of exterior finish are to be sealed or properly screened for insects and weather protection including but not limited to electrical lines, cable, water and gas pipes, AC condenser lines. CRC §R602.3.4.1
18. Where propane drains are necessary they shall terminate per code and Placer County handout. In areas at or above 5,000 ft. elevation, propane drains, when required, are terminated per approved design. CMC 303.8.1 & Placer Co. Handout.
19. Backflow preventers or vacuum breakers shall be installed at hose bibs with the set screw. Vacuum breaker on irrigation system shall be 6" above highest head. CPC §603.3.3, 603.5.7
20. Electrical outlets: A minimum of one accessible GFI protected outlet in front and one in rear of the dwelling not more than 6 1/2' ft. above grade and shall be labeled water resistant & be tamper resistant. CEC §210.52(E).
21. Water pressure regulator required when water pressure exceeds 80 PSI. and shall be approved type with an adequate strainer. CPC §608.2
22. Clean outs: install cleanouts within 2' feet of building and extended to grade with approved fittings or per P.U.D. CPC §715.1 & 719
23. Fire-safe driveway standards are met. Refer to handout. Fire-safe driveways located in the Tahoe area shall be approved by NTFPD and Alpine Meadows Placer Co. Ord. 15.04.710.6(0)

- 24. Clearance between wood siding and earth shall not be less than 6” unless sheathing and wall framing are naturally durable or preservative-treated wood. CRC §R317
- 25. Exterior Stucco/plaster weep screed clearance shall be a min. of 4” above earth or 2” above paving. CRC §R703.7.2.1
- 26. Receptacles in a wet location, unprotected by roofed open porch, canopies and alike, shall be GFCI and in an enclosure that is weatherproof whether or not the attachment plug cap is inserted. (Bubble Cover) CEC 406.9
- 27. Lighting: All exterior lighting mounted to the building or to other buildings on the same lot shall be high efficacy luminaries AND shall be controlled by a photo control and motion sensor combination and shall be listed for damp or wet location. Caulked seal around light fixtures is required. CEC §210.70 A (2) (b), 410.10 & Title 24 Energy code

A/C COMPRESSOR

- 28. A/C compressor(s) shall be indicated and located per approved site plan.
- 29. Disconnect shall be readily accessible and not more than 6’-7” above grade. (do not install disconnect behind unit.) CEC §440.14, Identification of equipment: For more than one unit permanent identification on A/C unit disconnect. CMC §303.6
- 30. Verify that circuit breaker &/or fuse are sized per name plate and line set caps are lockable. CEC §440.4
- 31. Verify that an accessible electrical receptacle is installed at the same level and within 25’ of the A/C unit. The outlet shall not be connected to the load side of the A/C disconnect. CEC §210.63

SAFETY GLASS REQUIRED CRC §R308

- 32. When edge of glass is less than 24” from door edge and less than 60” above ground.
- 33. When glass is more than 9 sq. ft. and edge of glass is less than 18” above floor/ground and top edge is more than 36” above ground and within 36” of walking surfaces.
- 34. When glass is within 60” of the water's edge at swimming pool, hot tub, spa, bathtub or shower.

VENT AND CHIMNEY TERMINATION

- 35. Chimney(s) terminations must be 2’ above any roof/structure within 10’ and not less than 3’ above the highest point where the chimney passes through the roof. See figure CRC §R1003
- 36. Spark arrester shall be approved, screened, accessible and removable for cleaning. CRC §R1003.9.2
- 37. Dryer exhaust duct termination: Duct shall terminate independently to the outside and be equipped with an approved back-draft damper (no screens). CMC §504.3
- 38. Environmental air duct exhaust such as hoods, dryer and bathroom vents shall terminate a min. of 3’ from property line and 3’ from openings into a building. CMC §504.5

39. Gas appliance "B" vents 12" or smaller shall terminate a min. of 12" above any portion of a building within 10' horizontally when 6:12 or flatter, see CMC Figure 8-2 for other roof pitch requirements. Vents shall be at least 8' from a vertical wall. All other vents shall terminate a min. of 2' above the highest point where they pass. Exception: Direct-Vent CMC §802.6.2, 802.8.1
40. Waste vents shall terminate vertically not less than 6" above roof, nor less than 1' from any vertical surface and 10' from or 3' above any opening such as windows, doors, air intake, nor less than 3' from any lot line. Side wall vent may not terminate under vented soffit. CPC §906.1

ROOF

41. All roofing materials have been properly installed per manufactures specifications, including step-flashings, counter flashings, and "crickets or splitters" behind chimneys as required. CRC Chapter 9
42. Above 4,000 ft. elevation plumbing vents, B-vents and chimneys not within 36" of the ridge on roof slopes 3&12 and greater are protected from sliding snow or ice with metal crickets or other approved means. Placer Co. Ord. §15.04.420.E
43. A completed "Certificate of Compliance" for Class A roofing shall be provided to the inspector
44. Provide leaf guards at gutters as per CRC §R337.5
45. Paint all ABS/Plastic vent pipes. IAPMO IS 9-2006 (Installation Standards), CPC §312.4

FLAT ROOF/BALCONY DRAINS

46. Primary drain(s) shall be properly sized per CPC Table 1101.11
47. Secondary drain(s) shall be the same size as the primary drain with the inlet flow line 2" above the low point of the roof and shall be an independent system OR overflow scupper(s) shall be installed with the inlet flow line located 2" above the low point of the roof and the scupper opening a min. of 4" high and have a width equal to the circumference of the primary drain. Overflow drains shall not be connected to the primary drain. CPC §1101.11.2.2, & 1105.2 & R903.4.1
48. Min. ¼" per foot slope to drain for Built-up roofs R905.9.1
49. Strainer(s) for flat deck primary drain(s) shall be level with the deck with the inlet area not less than 2 times the area of the drain pipe. CPC §1105.3
50. Strainer(s) for all flat roof secondary drain(s) shall be a min. of 4" above with the inlet area not less than 1-1/2 times the size of the inlet pipe. CPC §1105.2

GRADING AND DRAINAGE

51. Site Grading and Drainage per approved plan. Drainage away from foundations shall be a min. slope of 2% for 10' (6" in 10'). CRC §R401.3

VENTILATION

52. Indoor Air Quality and Mechanical Ventilation for all new dwellings and additions larger than 1,000sq.ft. All bathrooms require a minimum 50cfm 3-sone. Kitchen requires minimum 100cfm. 3-sone. 2019 California Residential Compliance Manual and the California Energy Standards Chapter 4.6
53. Ventilation system is labeled (Example: FAN MUST BE ON WHILE BUILDING IS OCCUPIED) and operation instructions provided for the homeowner. 2016 California Residential Compliance Manual and the California Residential Energy Standards 4.6
54. Roof/Attic: Min. net free ventilation 1/150 of the sq. ft. area. Openings to attics shall be covered with corrosion-resistant wire mesh where mesh openings are a min. of 1/16" not to exceed 1/8". CRC §R806
55. Under-floor: Min. net free ventilation 1/150 sq. ft. of area and placed within 36" of building corner as to provide cross ventilation of under-floor space. Openings shall be covered with corrosion-resistant wire mesh with mesh openings not exceeding 1/8" openings. CRC §R408

EXTERIOR GAS PIPING

56. Gas pipe passing through outside wall is protected against corrosion by coating, wrapping or sleeve, caulk around sleeve. CPC §1210.2
57. Gas meters, valves, and equipment are protected from sliding, drifting, and impact snow and ice. Where the ground snow is greater than 100 psf. there shall be a sign mounted directly above the gas meter, readily visible, above maximum anticipated snow depth. Per Fire Dept. and Placer Co. Ord. 15.04.420.D

GARAGE

58. Receptacle outlet: One receptacle outlet per vehicle is required in garages with electrical power. CEC §210.52 (G)
59. GFCI protection at all electrical receptacles. CEC §210.8
60. Exposed electrical cable within 7' from the floor shall be protected with rigid metal conduit electrical metallic tubing, or rigid nonmetallic conduit or other approved means. CEC §334.15 & 320.23
61. Gas appliances shall be protected from vehicular traffic with bollards (i.e. gas water heater, furnace, dryer) CPC §507.13.3 & CMC 3081.1
62. Attached and detached garages shall have at least (1) switch controlled light. Lighting shall be high efficacy AND be controlled by an occupant sensor CEC §210.70 (1), 2019 Residential Compliance Manual.
63. No openings are allowed between garage and sleeping rooms. CRC §R302.5.1
64. Door between house and garage to be 1-3/8" solid or honeycomb-core steel or labeled as a 20-minute door with self-closing and self-latching mechanism. CRC §R302.5.1

ELECTRIC PANEL

- 65. Circuit breakers to match manufacture of panel requirements.
- 66. Verify listed breakers. CEC §110.
- 67. Oxide inhibitor applied to aluminum conductor terminations in lugs/breakers. CEC §110.14
- 68. No double lugging allowed unless specifically approved. CEC §110.14.
- 69. Verify wire size complies with CEC §310 & table 310.15 (B) (16)
- 70. Main panel grounds and neutrals shall be on the same bus bar, or if on separate bus bars, the bus bars must be connected by a bonding jumper the same size as GEC. CEC §250.142
- 71. Sub panel grounds and neutrals shall be on a separate bus bar CEC §250.6
- 72. Unused K/O and openings shall be sealed with listed plugs CEC §110.12
- 73. Provide proper phasing for multi wire branch circuits.
- 74. Panels with more than 6 disconnects req. main breaker unless specifically approved. CEC §230.71
- 75. Panel boards at separate structures require a main disconnect and grounding electrode CEC §250.32
- 76. Dedicated circuit for furnace CEC §422.12
- 77. Dedicated circuit for heated Hydro-Massage bathtub motors. CEC §680.71
- 78. Min. (2) 20 amp small appliance circuits @ kitchen & dining, pantry & breakfast areas CEC §210.11
- 79. Min. (1) 20 amp circuit for laundry receptacle CEC §210.11
- 80. Min. (1) 20 amp circuit dedicated for bathrooms receptacles CEC §210.11
- 81. Bedrooms, Family Rooms, Dining Rooms, Living Rooms, Parlors, Libraries, Dens, Sunrooms, Recreation Rooms, Closets, Hallways or similar rooms or areas lighting and receptacle outlets shall be protected with AFCI and shall be independently identified/labeled as such. CEC §210.12
- 82. Verify labeling of circuits for main and Sub-panel. CEC §110.22
- 83. Handle tie at garbage disposal and dishwasher breaker for multi-wire branch circuits where same box is used. Label receptacle. CEC §210.4
- 84. Grounding electrode and GEC per CEC-table §250.66 & articles 250.64, 250.70.
- 85. Main disconnect 6'-7" from top of handle to floor/grade and location is readily accessible clearance of 36" deep X 30" wide X 78" in height. CEC §404.8, 230.70
- 86. Overcurrent devices shall be readily accessible, therefore in areas at or above 5,000 ft. elevation, the sub-panel is located at the interior or where not subject to snow build-up. CEC § 240-24

87. Internal parts/equipment shall not be damaged and free of contaminates. CEC §110.12 90
88. Electrical panel shall be clean of debris. Contaminated panel must be replaced. §CEC110.12

GUARDS AND HANDRAILS

89. Guards are required along open-sided walking surfaces 30" above grade/floor. CRC§R312
90. Guard height: Guards shall not be less than 42" high measured vertically above the leading edge of the tread except when stair handrail is the guard then min. height 34" and max. height 38". CRC §R312
91. Hand rails shall have a height of not be less than 34" and not more than 38" and should have returns, top and bottom. CRC §R311.7.8
92. Guard assemblies shall resist a single concentrated load of 200 pounds. CRC Table R301.5
93. Graspability: circular handrail shall be Min. 1-1/4" Max. 2" diameter. Non-circular handrails must have a perimeter of 4" min. and 6-1/4" max. with a max. cross dimension of 2-1/4". CRC §R311
94. Handrails are required on one side with four or more risers. CRC §R311.7.8
95. Clear space between hand rail and wall a min. of 1-1/2". CRC §R311
96. Projection: Handrail projection into stairway a max. of 4-1/2". CRC §R311
97. Openings: guards shall not allow a 4" sphere to pass through. CRC §R312
98. Openings: guard rails on the side of stair treads shall not allow a 4-3/8" sphere to pass through and the triangular opening at bottom of tread & riser shall not allow a 6" sphere to pass through. CRC §R312

STAIRWAYS

99. Width: Stairway width shall not be less than 36" CRC §R311
100. Headroom: Min. 6'-8" (Spiral 6'-6") CRC §R311
101. Treads and risers: Maximum riser height shall be 7-3/4" and a minimum of 4" Minimum tread depth shall be 10" with a min. 3/4" nosing or 11" depth. CRC §R311
102. Nosing: max. radius of curvature or beveling of nosing 1/2". Risers shall be solid and require nosing min. 3/4" max. 1-1/4" except when tread depth is 11" nosing is not required. CRC §R311
103. Dimensional uniformity at stairs shall be determined from landing to landing from the tallest riser not more than 3/8" to the shortest riser and greatest tread depth not more than 3/8" more than the smallest. CRC §R311

104. Winder Treads: Shall have a tread depth of not less than 10" measured between vertical planes of the foremost projection of the adjacent treads at the intersections walk-line. Tread depth shall not be less than 6" at any point within the clear width of the stair. The winder's tread depth at the walk line shall not exceed the smallest by more than 3/8". CRC §R311.7.5.2.1
105. Doors are permitted to open at the top step of an interior flight of stairs, provide the door does not swing over the stairs. CRC §R311
106. Stairway landing there shall be a landing at the top and bottom of each stairway. The width of landings shall not be less than the width of the stairway they serve. Every landing shall have a stairway dimension measured in the direction of travel with a min. 36"
CRC §R311
107. Vertical rise: Max. 151" between floor levels or landings. CRC §R311
108. Lighting is required on tread runs not less than 1 foot-candle. Where one or more lights are installed for stairway provide a wall switch at each floor level and landing level that includes an entry (fluorescent or push button control occupant sensor) CRC §R303.7
109. Safety glass required in walls enclosing stairway landings or within 5' of the bottom of stairway where the bottom edge of the glass is less than 36" above a walking surface. CRC §R308

EXTERIOR STAIRWAY LOCATIONS

110. Outdoor stairways and landings shall be designed to shed water. CRC §R311
111. Lighting is required at all landings at exit doors and tread runs at stairways. (photo control/sensor combination) CRC §R303.7

THRESHOLD CLEARANCE TO LANDING

112. Door that swing out over landings: Max. threshold height above exterior landing 1½"
CRC§R311
113. Door swings in or slider: Max. threshold height above exterior landing 7¾" CRC§R311

LANDINGS

114. Exterior landings at doors: The width shall not be less than the width of the stairway or door, whichever is greater. Landing length in direction of travel shall be a min. of 36". Outdoor stairways and landings shall be designed to shed water a min ¼" per foot away from house. CRC §R311.3
115. Landings at exterior doorways shall not be more than 7.75" below the top of the threshold, provided the door does not swing over the landing. CRC §R311.3.2
116. Landings for other than the required egress door are not required where a stairway of two or fewer risers is located on the exterior side of the door, provided the door does not swing over the stairway. CRC §R311.3.2

INTERIOR

117. Ceiling height in all habitable spaces shall be no less than 7'. CRC §R305
118. All receptacles and switches shall be complete with plates.

UNDER-FLOOR CRAWL SPACE

119. Under floor foundation access crawl hole openings min. 18"x24" (pipes, ducts and other nonstructural construction shall not interfere with the accessibility to or within under-floor areas.) CRC §R408
120. Remove all debris from crawl space. CRC §R408
121. Verify that all under-floor vents are clear (not blocked.) CRC §408
122. In areas at or above 5,000 ft. elevation, hot and cold water supply piping is installed for winterization, freeze protection and routine drain down. The water supply shall be equipped with a readily accessible shut off valve. Placer Co. Ord. §15.04.420.C

KITCHEN

123. Ceiling height shall be min. 7' in kitchen CRC §R305
124. Listed air-gaps shall be provided for dishwasher on discharge side and be mounted on counter top. CPC §807.4
125. All receptacles serving the countertop shall be GFCI/AFCI protected CEC §210.8
126. Wall counter top receptacles shall be spaced max. 48" on center and within 24" from edge of the sink and counters. CEC §210.52
127. Counter tops 12" or more in width require a receptacle outlet. CEC §210.52
128. Islands and peninsulas shall be provided with a min. of (1) receptacle unless considered separate counter spaces. CEC §210.52 (C) (1), (2), (3) and (4)
129. Outlets shall not be mounted over 20" above counter top nor more than 12" below counter. CEC §210.52 (C) (5)
130. Provisions for range must be present either as a capped off gas line or a 220 volt outlet installed in wall. If stove is to be wired directly, it shall be hooked up for inspection.
131. Kitchen range clearance to combustibles shall have a vertical clearance of 30" unless
132. protected by ¼" insulating millboard or metal hood, then the clearance can be reduced to 24". Gas range must have approved anti-tip installed. CMC §916.1.2.

133. Range hood exhaust duct shall terminate outside, shall have a 3' clearance to windows and doors and other openings, shall be air tight and be equipped with a back draft damper. Ducting shall be galvanized steel, stainless steel, or copper, with a smooth interior finish. CMC §504.2 & 504.5 If the hood vent is used for indoor air quality or mechanical ventilation, it shall comply with the 2016 Residential Compliance Manual Section 4.6 and CEC 150 (e)
134. Shut-off valve shall be accessible rigid piping upstream from the flexible connector and within 6' of the gas appliance. CPC §1212.5
135. Gas appliance connectors shall not extend from one room to another, through any wall, floor, partition or appliance housing. Verify that connector is the properly sized and listed for the appliance it serves. (See BTU rating on connector tag.) CPC §1211
136. Junction boxes shall be accessible.
137. Kitchen lighting shall be all high efficacy and be controlled by a vacancy sensor OR 50% of total wattage may be low efficacy, all low efficacy and high efficacy lighting shall be switched/controlled separately 2016 Residential Compliance Manual.

WET BARS

138. GFCI protection required for receptacles located within 6' of wet bar sink edge. CEC§210.8 (A)(7)

BEDROOMS AND DENS (W/CLOSET)

139. Smoke alarms shall be interconnected, hardwired with battery backup, are required on ceiling or wall at each floor level, in each bedroom and outside each sleeping area. CRC314
140. Carbon Monoxide Alarms shall be installed in dwellings with fuel burning appliances and with attached garages. Detectors shall be interconnected. Detectors shall be installed outside each sleeping room area and every floor level including basements. CRC §R315
141. Bedrooms, Basements, and Habitable attics window egress min. clear height 24", min. clear width 20", min. 5.7 sq. ft. open able area except at grade floor may be 5.0 sq. ft. The bottom on the clear opening shall have a max. height of 44" measured from the floor. CRC §R310
142. Lighting shall be high efficacy and controlled by an occupant sensor. Closets that are less than 70 sq. ft. are exempt from this requirement.
143. Closet light clearances: Surface incandescent lights shall be fully enclosed and a min. of 12" clearance from storage/shelf area. Fluorescent lights shall be a min. 6" from storage/shelf. Recessed lights in wall or ceiling shall be a min. 6" from storage area. CEC 416 (C)

HALLWAYS

144. The minimum ceiling height in a hallway is 7'. CRC §R305

145. The minimum width of the hallway 36" CRC §R311
146. Smoke alarms are required in the immediate vicinity of the bedrooms. (min. 3' away from supply air register, bathroom door, paddle fan or per manufacturer's instructions) CRC §R314
147. Carbon Monoxide Alarms shall be installed in dwellings with fuel burning appliances and with attached garages. Detectors shall be interconnected and installed outside each sleeping room area and every floor level including basements, multiple purpose smoke and carbon monoxide alarms are acceptable. CRC §R315
148. Hallways 10' or more in length require min. (1) electric receptacle. CEC §210.52(H)

LAUNDRY ROOMS

149. Lighting shall be high efficacy and controlled by an occupant sensor.
150. The minimum ceiling height in a laundry room is 7 feet. CRC §R305
151. GFCI protection required for receptacles located within 6' of laundry sink edge. CEC §210.8 (A) (7)
152. Shut-off valve shall be accessible rigid piping upstream from the flexible connector and within 6' of the gas appliance. CPC §1212.5
153. Gas appliance connectors shall not extend from one room to another, through any wall, floor, partition or appliance housing. Verify that connector is the properly sized and listed for the appliance it serves. (See BTU rating on connector tag.) CPC §1211
154. Flexible dryer transition ducts: Shall be listed and approved, not more than 6' long and shall not be concealed within construction. CMC §504.3.2.1
155. Dryer duct min. 4" dia., 26 gage metal, smooth interior (no screws), max. 14' long including (2) 90 degree elbows and shall terminate to the outside with a back draft damper. (no screens allowed) CMC §504.3

BATHROOMS

156. The minimum ceiling height in a bathroom is 7' feet. CRC §R305
157. All hardwired lighting shall be high efficacy AND controlled by a vacancy sensor. CEC section 150(K)
158. Hanging light fixtures: are not allowed within 3' horizontal and 8' vertical from tub rim and shower threshold. CEC §410.10 (D)
159. Bathroom receptacles are to be supplied by at least one 20 amp circuit with no other outlets. Exception, if 20 amp circuit supplies only one bath room, other outlets within the same bath room are allowed on that circuit. CEC §210-11 (C) (3)
160. Light fixtures in shower shall be suitable for damp locations CEC §410.10

161. GFCI protection shall be provided for all outlets in bathrooms, with at least one outlet 36" inches of the outside edge of each basin. CEC §210-8(a) (1) & 210-52 (d)
162. Hydro Massage bathtub motors shall be accessible, on a dedicated circuit with their own GFCI circuit and bonded with min. 8 AWG copper wire. CEC §680.72 and 74, CPC §414.1.
163. Water closet spaces shall be at least 30 inches wide; 15" min. from wall to center of W/C with at least 24 inches clear in front of the W/C. CPC §402.5.
164. Water closet base caulked at floor. All new water closets shall be 1.28 gallon per flush maximum CPC §403.2.1
165. Safety glazing at all windows less than 60" above bottom of tub & shower floor and within 60" horizontally of the water's edge of the tub or shower. CRC §R308
166. Shower enclosure doors shall maintain an unobstructed opening of 22" clearance for egress CPC §411.6
167. Shower compartment min. 1024 sq. in. encompassing a 30" circle CPC §411.7
168. Bathroom fans shall be controlled by a humidity control switch unless part of the whole house ventilation system. CAL Green 4.506

ADDITIONAL WINDOW REQUIREMENTS CRC 312.2.1

169. Openable windows 72" inches or more above exterior grade must be at least 24" above the finished interior floor OR maximum window opening that would not allow 4" sphere to pass through OR install window control device per ASTM F2090. CRC §R312.2

GAS FIREPLACES

170. Shut-off valve shall be accessible rigid piping upstream from the flexible connector and within 6' of the gas appliance CPC §1211.5.
171. Gas appliance connectors shall be used in accordance with the terms of their listing, shall not extend from one room to another, through any wall, floor, partition or appliance housing. Verify that connector is properly sized and listed for the appliance it serves. (See BTU rating on connector tag.) CPC §1211.1.
172. All gas fueled fireplaces are required to be direct-vent sealed-combustion type. Any installed wood stove or pellet stove shall comply with U.S. EPA New Source Performance Standards (NSPS) and have a permanent label indicating they are certified to meet emission limits. Fireplaces are required to be listed on the EPA's approved list for emission standards. See §4.503 CAL Green and Placer County Code, Rule 225.

WATER HEATER

173. Shut-off valve shall be accessible, installed in rigid piping upstream from the flexible connector and within 6' of the gas appliance. CPC §1211.5.

- 174. Gas water heater located in garage shall be elevated 18" above floor.
- 175. Seismic strapping within upper 1/3 and lower 1/3 and min. 4" above controls. CPC §507.2.
- 176. Fullway shut off valve installed on the cold water supply pipe of the water heater CPC §606.2.
- 177. Combustion air is required to be provided. CPC §506, CMC §701.
- 178. Type B (double wall) vent may pass through floors and ceilings with a min. 1" clearance to combustibles or per manufacture listing. Type B vent shall terminate a min. 5' above water heater draft hood. Secure joints with min. 3 screws. CPC §509.6.2.1.
- 179. Water heater shall be protected from vehicular traffic (install bollard) CPC §507.13.1.
- 180. Water heater located at wood floor or attic shall be protected with watertight pan with 3/4" drain to approved location. (i.e. attic, floor-ceiling, platform) CPC §507.4.
- 181. Water heater installed in a closet located in a bedroom or bathroom shall have a listed, gasketed door assembly and a listed self-closing device with no hold open mechanism. The door assembly shall be installed with a threshold and bottom door seal. All combustion air shall be obtained from the outdoors. CPC §504.1(1), §506.4.
- 182. All water heaters require a thermal expansion tank.
- 183. Temperature and pressure relief valve (TPRV) shall terminate to the outside or other approved location with 3/4" discharge pipe pointing down, terminating a min. 6" and max. 24" above grade. Pressure relief valve piping to be hard drawn copper or galvanized steel or CPVC. PVC shall not be used, and drain is not allowed to drain into water heater pan. CPC §504, §507.5 & §608.5.

FURNACE GENERAL REQUIREMENTS

- 184. Manufacture's installation and operating instructions: The appliance installer shall leave the manufacturer's installation and operating instructions attached to the appliance. CMC §302.1
- 185. LPG fired appliances are installed in compliance with Placer County handout; Propane Appliance. CMC §308.7.
- 186. Required clearances from combustibles. CMC §903.3 & §904.2.
- 187. Combustion air requirements have been met per the manufacture's installation manual, CMC §802.8.1, CMC §802.8.2, and CMC chapter 7.
- 188. Gas shutoff valve: CPC §1211.5. Shall be in an accessible location and within 6' from the furnace. Connected to rigid piping upstream from the flexible connection in the same room as the furnace.
- 189. Disconnect shall be adjacent to and within sight of furnace. CMC §310.1.
- 190. Dedicated circuit shall be provided for furnace CEC §422.12.

191. Access: Furnace shall be accessible for inspection, service, repair, and replacement without removing permanent construction. CMC §304.1.
192. Anchorage: Furnace shall be securely fastened in place to sustain vertical and horizontal loads per manufacture's specifications. CMC §304.4.

FURNACE IN ATTIC

193. Shall be accessible through an opening and passageway not less than the largest component of the appliance and not less than 22" x 30". CMC §904.10.
194. Electrical wiring shall be protected within 6' of attic access scuttle opening to a height of 7' above the bottom of the rafters/trusses. CEC §334.23.
195. Passageway Min. 24" wide, unobstructed, solid flooring. CMC §904.10.2.
196. Max. 20' from access to appliance if passageway is less than 6' high. CMC §904.10.1.
197. Min. 30"x30" level working platform at front or service side of unit. CMC §904.10.3.
198. Light and receptacle outlet required. Light switch shall be located at attic entry and receptacle outlet within 25' of furnace. CMC §904.10.4.
199. Properly support and secure unit per manufacture's specifications. CMC §303.4.

FURNACE UNDERFLOOR

200. Shall be accessible through an opening and passageway not less than the largest component of the appliance and not less than 22" x 30". CMC §904.10.
201. Where excavation is necessary for installation, it shall extend a minimum 6" below and 12" all sides of furnace except the service side which shall be a minimum 30". CMC §904.3.1.3.
202. Where the depth of the excavations for furnace or passageway exceed 12", the walls shall be lined with concrete or masonry a minimum of 4" above adjoining grade. CMC §904.3.1.3.
203. Secure unit in place per manufacture's specifications. CMC §303.4.
204. Light and receptacle outlet required near appliance. CMC §904.11.4.
205. LPG fired furnaces are installed in compliance with Placer County handout; Propane Appliance. CMC §303.8.1.

FURNACE IN GARAGE

206. Ignition min. 18" above floor. CMC §308.1.
207. Protection from moving vehicles. (install bollard(s) CMC §308.1.
208. Gas burning appliance venting shall comply with manufacture's specifications and CMC§802.6.
209. High efficiency gas appliance: Vent termination per manufacture's specifications and CMC §802.8.1 and §802.8.2.

BASEMENT

- 210. Habitable basements shall have a min. of one exterior emergency escape and rescue opening. CRC §R310.1.
- 211. Egress opening shall not be less than 5.7 sq. ft. with a min. net height of 24” and net width of 20” and not more than 44” from floor to the bottom of clear opening (ladder required, if window well over 44” below grade. CRC §R310.
- 212. Window well egress: Window wells shall have a min. horizontal area of 9 sq. ft. with a min. dimension of 36”. Window well with a vertical depth of more than 44” shall be equipped with an approved permanently affixed steps OR ladder that does not project more than 6” into a 36” egress area, Verify proper guardrails, ladders and drainage. CRC §R310.2, and CRC §R310.21.
- 213. Electrical outlets in unfinished basements require GFCI protection. CEC §210.8 (A) (5).

EJECTOR PUMP

- 214. Each ejector or pump shall have a minimum 2” accessible approved swing check or backwater valve and full way Gate or ball valve. CPC §710.3. (2).
- 215. Sump tank shall have a bolt-and-gasketed cover. CPC §710.10.
- 216. Ejector vent shall be run separately through roof, vent size per table 7-3 but never smaller than 1-1/2”. CPC §710.10.
- 217. Ejector pump and valves shall be accessible for maintenance and replacement. Provide electrical outlet and lighting at or near the pump. CPC §710.6 and CEC §210.63.
- 218. Receptacle outlet shall not be located in pit. Install receptacle min. 12” above floor level.

I have personally reviewed all items on this list for completion prior to scheduling the inspection.

Signed _____

Date _____

Print Name _____