



**City of Grass Valley  
Building Department**  
125 East Main Street  
Grass Valley, CA 95945  
(530) 274-4340

[www.cityofgrassvalley.com](http://www.cityofgrassvalley.com)

**Nevada County  
Building Department**  
950 Maidu Avenue  
Nevada City, CA 95959  
(530) 265-1222

[www.mynevadacounty.com](http://www.mynevadacounty.com)

**City of South Lake Tahoe  
Building Department**  
1052 Tata Ln.  
South Lake Tahoe, CA 96150  
(530) 542-6010

[www.cityofslt.us](http://www.cityofslt.us)

**Placer County Building Department**  
3091 County Center Drive  
Auburn, CA 95603  
(530) 745-3010

**Tahoe Office**  
775 North Lake Blvd  
Tahoe City, Ca 96145  
(530) 581-6200

[www.placer.ca.gov](http://www.placer.ca.gov)

**Town of Truckee  
Building & Safety**  
10183 Truckee Airport Road  
Truckee, CA 96161  
(530) 582-7820

[www.townoftruckee.com](http://www.townoftruckee.com)

**Sierra County  
Building Department**  
101 Courthouse Square  
Downieville, CA 95936  
(530) 289-3251

[www.sierracounty.ca.gov](http://www.sierracounty.ca.gov)

**Town of Mammoth Lakes  
Building Department**  
437 Old Mammoth Road, Suite 230  
Mammoth Lakes, CA 93546  
(760) 965-3630

[www.townofmammothlakes.ca.gov](http://www.townofmammothlakes.ca.gov)

***"Partnering to Improve Consistency & Customer Service"***

## 2019 CA Plumbing Code Substantial Changes

***(Effective January 1, 2020)***

- Definition change of appliance to include a device that utilizes compressed fuel gas. (Ch. 2)
- All non-compliant fixtures shall be replaced with water conserving plumbing fixtures. (Changed from when undergoing alterations) (401.3)
- Shower head flow rates reduced from 2.0gpm to 1.8gpm. (408.2.1)
- Shower receptor slope reduced to 1/8" per foot of slope from 1/4" (408.5)
- Flushometer toilets reduced to 1.28 gallons per flush from 1.6 gallons. (411.2.2)
- Tracer wire size increased from 18awg to 14awg for underground water supply lines. (604.10.1)
- The volumetric flow rate of gas to be provided shall be adjusted for altitude when the installation is above 2000 ft. Old language just mentioned to adjust for altitude. (1208.4.1)
- Thermostatic mixing valves required for emergency eyewash stations. (416.2)
- Gas piping installed on roof surfaces shall be elevated above the roof surface and properly supported. (1210.2.4.3)
- CSST bonding jumper point of connection shall not exceed 75ft from the grounding electrode system. (1211.2.3)