



| | |
|----------------------------|-------|
| FOR OFFICE USE ONLY | |
| Amt Due: | _____ |
| Date Received: | _____ |
| Receipt #: | _____ |
| Invoice #: | _____ |
| Permit SR #: | _____ |

Department of Health and Human Services, Environmental Health Division
 Auburn Office: 3091 County Center Drive, Suite 180, Auburn, CA 95603 (530) 745-2300
 Tahoe Office: 775 N Lake Blvd, Suite 203, Tahoe City, CA 96145 (530) 581-6240

APPLICATION FOR UNDERGROUND STORAGE TANK

NEW CONSTRUCTION

MODIFICATION

REPAIR

OWNER DETAILS:

Name: _____
 Mailing Address: _____
 Phone: _____ Email: _____

FACILITY DETAILS:

Name: _____
 Mailing Address: _____
 Phone: _____ Email: _____

CONTRACTOR DETAILS:

Name: _____
 Mailing Address: _____
 Phone: _____ Email: _____

SCOPE OF WORK:

Persons performing installation, modification, or repair of underground storage tank (UST) systems, which includes tanks, piping, secondary containment components, and monitoring equipment (and persons employed by same), shall meet the following requirements:

- ❖ Possess one of the following Contractors State License Board (CSLB) license type and a Hazardous Substance Removal Certification:
 - Class A General Engineering
 - C-10 Electrical Contractor
 - C-36 Plumbing Contractor
 - C-61 (D-40) Limited Specialty Service Station
 - C-34 Pipeline Contractor
- ❖ Be trained and certified by the manufacturer of the tank(s), piping and monitoring equipment.
- ❖ Be re-certified by the manufacturer by completion of a manufacturer's refresher course. Certification shall be renewed at the time interval recommended by the manufacturer, or every 36 months, whichever is less.

The completed application must include the following:

(Incomplete applications will not be reviewed)

1. A certified copy of worker's compensation insurance.
2. A detailed, written summary of the project, including a timeline.
3. A complete list (including manufacturer's name, specific model #, and U.L. or equivalent listing information) of all equipment proposed including the following:

| | | |
|---|--|---|
| <ul style="list-style-type: none"> • Tank(s) • Tank trim • Overfill Prevention • Overspill Containment • Tank Probes • Tank Annular Space Monitoring Sensor • Turbine/Suction Pump | <ul style="list-style-type: none"> • Product Piping • Secondary Product Piping • Vent and Vapor Piping • Piping Sumps • Piping Sump Monitoring Sensors • Sump Fittings | <ul style="list-style-type: none"> • Line Leak Detector(s) • Monitoring Console • Under Dispenser Containment (UDC) Sump • UDC Monitoring Equipment |
|---|--|---|



Department of Health and Human Services, Environmental Health Division

Auburn Office: 3091 County Center Drive, Suite 180, Auburn, CA 95603 (530) 745-2300

Tahoe Office: 775 N Lake Blvd, Suite 203, Tahoe City, CA 96145 (530) 581-6240

APPLICATION FOR UNDERGROUND STORAGE TANK(continued)

- 4. Detailed plot plan showing any all existing structures, tanks, piping and utility fixtures.
5. A complete set of scaled construction plans stamped and signed by a professional engineer.
6. Copies of current installation training certificates issued by the manufacturer for: Tank(s), Piping, Monitoring Equipment
7. A tank buoyancy, anchoring and ballasting design prepared by a professional engineer.
8. Completed fee disclosure form.

Please be Advised:

- All work must conform to the design, construction and monitoring requirements of Article 3 of the California Underground Storage Tank Regulations, Title 23, California Code of Regulations.
All applicable encroachment, building, air pollution control district, fire department and other agency requirements, permits and approvals must be obtained as needed.
All necessary and appropriate agency approvals, i.e., building department and fire authority, must be obtained prior to introducing fuel into the tank system(s) for any purpose including tightness testing.
Compliance with the California Fire Code and related requirements is the responsibility of the owner, and the contractor.
All underground storage tanks subject to floatation shall be anchored using methods specified by the manufacturer or, if none exists, shall be anchored according to the best engineering practice.
Plan revisions/re-submittals must be clearly designated as such (e.g. cloud and date changes).
This office does not review or approve site-specific health and safety plans for adequacy, accuracy, or completeness.
This application will be reviewed to assure that the intended activity meets the requirements of Chapter 6.7 of the California Health and Safety Code and Chapter 8 of the Placer County Code.

Note: If work is to be done, which involves existing tanks or lines, it is strongly recommended that a contingency plan be developed and submitted with the project plans to deal with the possibility that contamination may be encountered and to minimize construction delays. A qualified consultant must prepare the contingency plan.

LIABILITY FOR DAMAGES:

The applicant/permittee shall defend, indemnify, and hold harmless Placer County, and its agents, officers, and employees, from all claims, liability, damages, costs, lawsuits, and judgments for property damage, for personal injury, for construction costs or claims which may arise out of or be alleged to relate to applicant's/permittee's work performed under a permit, excepting for any actual damages which may be proven to have arisen solely out of the active negligence of the County.

Contractor's Name Printed: _____ CSLB License #: _____

Contractor's Signature: _____ Date: _____

Owner's Name Printed: _____

Owner's Signature: _____ Date: _____