



# Health and Human Services Department Placer County Environmental Health

## DAILY POOL AND SPA LOG SHEET

Facility Name				Person of Responsibility				Hours of operation		Month/Year	
Facility Address				Contact phone #/email				Volume (gals) Pool _____ Spa _____		Area (sq. ft.) Pool _____ Spa _____	
DATE	Free Chlorine		pH		Flowmeter		Temp	Remarks (chemicals added, replace drain covers, backwash filter, etc...)	By		
	Pool	Spa	Pool	Spa	Pool	Spa					
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											

Monthly Test Date	Cyanuric Acid <100 ppm		Calcium Hardness 150-1000		Total Alkalinity 80-180		Other
	Pool	Spa	Pool	Spa	Pool	Spa	

**NOTE: The pool operator shall test for free Cl<sub>2</sub>, pH, and Spa temperature on a daily basis** (Exception – complexes with fewer than 25 units may record required information at least 2 times per week with no more than 4 days between readings per sec 116048); **maintain written records of these test results and corrective action taken at the public pool site (sec 65523). Maintain data for at least two years.**