



REASONS FOR POOL/SPA/WADING POOL/SPRAY GROUNDS CLOSURE

The FACILITY will be **CLOSED** if any of the following conditions are found to exist:

- Main drain(s) cannot be seen due to poor water quality
- Main drain(s) or any suction cover(s) missing, loose, or broken
- Heavy algae growth
- No Chlorine or Bromine residual
- Excessive chlorine residual (greater than 10 ppm)
- Excessive cyanuric acid (greater than 100 ppm)
- Underwater light(s) loose or missing
- Emergency spa pump shut off switch broken/not working properly
- Inoperable automatic chlorinator, or UV (less than 40 mJ/cm² for spray grounds)
- Inoperable filtration system
- Fecal accidents
- Any other condition which may be found to exist and can't be immediately corrected which could actually or potentially threaten the health, welfare and safety of the public (i.e. gates locked in open position, large holes in pool shell, sharp objects like broken glass in the pool or pool enclosure, lacking rescue equipment, entrapment and inhalation hazards, unwanted pests or birds, flooding, etc...)

NOTE: ONCE OUR DEPARTMENT HAS BEEN NOTIFIED BY THE OWNER OR OPERATOR THAT THE CONDITION (S) FOR WHICH THE RECREATIONAL FACILITY HAD BEEN CLOSED IS CORRECTED; EVERY EFFORT WILL BE MADE TO RE-INSPECT AND RE-OPEN THE POOL/SPA/WADING/SPRAY PARK AS QUICKLY AS POSSIBLE. HOWEVER, THIS CAN BE AFFECTED BY STAFFING, PRIOR COMMITMENTS, HOLIDAYS OR OTHER CONDITIONS.